

ORD Article 1, Chapter 5 Building Code 16-629- ATTACHMENT A

TABLE 404.2.4.1

PERFORMANCE CRITERIA FOR CBC LEVEL SEISMIC FORCES

OCCUPANCY CATEGORY (BASED ON TABLE 1604.5)	PERFORMANCE LEVEL FOR USE WITH ASCE 41 BSE-1 EARTHQUAKE HAZARD LEVEL	PERFORMANCE LEVEL FOR USE WITH ASCE 41 BSE-2 EARTHQUAKE HAZARD LEVEL
I	Life Safety (LS)	Collapse Prevention (CP)
II	Life Safety (LS)	Collapse Prevention (CP)
III	Note a	Note a
IV	Immediate Occupancy (IO)	Life Safety (LS)

- a. Acceptance criteria for Occupancy Category III shall be taken as 80 percent of the acceptance criteria specified for Occupancy Category II performance levels, but need not be less than the acceptance criteria specified for Occupancy Category IV performance levels.