

ORD Article 1, Chapter 5 Building Code 16-629-ATTACHMENT B

**TABLE 404.2.4.2
PERFORMANCE CRITERIA FOR REDUCED CBC
LEVEL SEISMIC FORCES**

OCCUPANCY CATEGORY (BASED ON CBC TABLE 1604.5)	PERFORMANCE LEVEL FOR USE WITH ASCE 31	PERFORMANCE LEVEL FOR USE WITH ASCE 41 BSE-1 EARTHQUAKE HAZARD LEVEL
I	Life Safety (LS)	Life Safety (LS)
II	Life Safety (LS)	Life Safety (LS)
III	Note a, Note b	Note a
IV	Immediate Occupancy (IO)	Immediate Occupancy (IO)

- a. Acceptance criteria for Occupancy Category III shall be taken as 80 percent of the acceptance criteria specified for Occupancy Category II performance levels, but need not be less than the acceptance criteria specified for Occupancy Category IV performance levels.
- b. For Occupancy Category III, the ASCE screening phase checklists shall be based on the life safety performance level.