

Council District	Distress Location	Repair Description
5	Durant Ave between Myers Ct and Kenilworth Ave	Replace entire line segment and also one brick manhole
5	Durant Ave at Myers Ct	Replace MH 300+60 (PVC-lined) and repair broken line segment to the east
5	Broadmoor Blvd at Macarthur Blvd	Replace damaged pipe
5	Broadmoor Blvd at Macarthur Blvd	Replace damaged pipe
5	1180 Victoria Ave	Replace frame and cover
5	918 Alice Ave	Re-channel manhole
5	958 Alice Ave	Replace manhole
5	230 W Broadmoor Blvd	Replace 28' of pipe from 212' to 240' downstream
5	124 Sunnyside Dr	Replace frame and cover
5	Sunnyside Dr at Breed Ave	Remove 4' pipe and replace brick manhole
5	642 Dowling Blvd	Replace 9' of pipe immediately downstream of MH 341+26
5	E 14th St at Georia Way	Replace manhole (PVC-lined)
1	Cary Dr at San Jose St	Storm drain reconfiguration
5	1166 Glen Dr	Replace CO with MH (no-PVC). Construct 90' new sewer
1	Rodney Dr at Cary Dr	Rechannel manhole with mortar
1	1010 Bridge Rd	Replace manhole. Replace line segment through pipe-bursting. Upsize from 6" VCP to 8" HDPE. Extend pipe to Estudillo and add new manhole.
1	Brookvale Dr at Daniels Dr	Open trench to replace pipe, which has multiple sags/risers.
5	Cambridge Ave at E. 14th St	Replace manhole (PVC)
5	Garcia Ave at E. 14th St	Replace manhole (PVC)
5	Lorraine Blvd at Lafayette Ave	Reconfigure merge per detail, replace 108 to 110 and 224 to 228
1	1135 Sandelin Ave	Remove 5' of pipe (hand-dig)
5	282 California Ave	Replace manhole (no-PVC)
5	372 Toler Ave	Replace with new Type A manhole
5	399 Arroyo Ave	Replace line with 6" C900 PVC and replace brick manhole
5	332 Arroyo Ave	Replace manhole (no-PVC)
5	Callan Ave 60' east of E. 14th St	Replace 2' pipe starting at 100.5' downstream
1	Juana Ave at Santa Maria St	Replace 2' pipe
1	Dolores Ave at Bancroft Ave	Remove 3' of pipe
1	Maud Ave at E. 14th St	Remove and replace 2' from 394' to 396' downstream.
1	1690 E. 14th St (Maud Ave side)	Remove and replace 8' from 355' to 363' downstream. Eliminate lamphole at 356' downstream.
1	1890 E. 14th St (Maud Ave side)	Remove and replace 5' from 342' to 347' downstream
1	249 Maud Ave	Remove and replace 2' from 156' to 158' downstream
1	348 Maud Ave	Replace MH 213+15 (PVC-lined)
1	348 Maud Ave	Remove and replace 2' from 630' to 632' downstream
1	397 Maud Ave	Remove and replace 6' from 315' to 321' downstream
1	451 Maud Ave	Remove and replace 3' from 101' to 104' downstream
1	485 Maud Ave	Replace MH 213+17 (PVC-lined). Remove and replace pipe segment from 0' to 2' downstream.
2	867 Kenyon Ave	Replace with new Type A manhole (no-PVC)
1	1218 Ardmore Dr	Replace 18' of pipe from 85' to 103' downstream of MH 190+08
1	Benedict Dr approximately 15' south of Ardmore Dr	Replace 20' of pipe from 219' to 239' downstream of MH 190+09
1	1201 Sandelin Ave	Remove and replace 15' of pipe (hand-dig)
1	Castro St at Hays St	Replace manhole (no-PVC)
3	1712 Pacific Ave	Re-channel manhole, replace 3' of pipe 191.5 to 194.5 downstream
3	Harlan St at railroad tracks approximately 490' west of San Leandro Blvd	Fix pipe break towards MH 107+19 a few feet away from 107+03.
1	Washington Ave at Estabrook St	Replace with new Type A manhole (PVC-lined)
1	2252 E 14th St	Replace manhole (PVC-lined) and pipe segment 110-113 feet upstream
1	508 Marina Blvd	Replace pipe upstream of MH. Also need to smooth out MH shelves with mortar
1	Cherry St at 2nd Ave	Replace with new Type A manhole (PVC-lined)
6	Carden St at Davis St	Replace frame and cover with composite type
6	Carden St at Davis St	Replace frame and cover with composite type
6	195' east of Carden/Davis	Replace frame and cover with composite type
6	265' west of Beecher/Davis	Replace frame and cover with composite type
6	Underneath Bridge @ Beecher/Davis	Replace frame and cover with composite type
6	Underneath Bridge @ Beecher/Davis	Replace frame and cover with composite type
5	Dorchester Ave at Farrelly Dr	Merge from MH 303+01 needs to be smoother. Add new MH (no-PVC)
5	397 Farrelly Dr	Replace frame and cover with composite type
6	2059 Reynolds St	Replace 3' pipe from 124' to 127' upstream 021+13; replace 3' pipe 133' to 136' upstream 021+13
6	North Blvd	Replace sagging portion of sewer main
6	West of Reynolds St	Remove 3' pipe to take out spike
6	1126 Davis St	Uncover MH and adjust frame and cover to grade
6	1126 Davis St	Uncover MH and adjust frame and cover to grade
6	Virginia St at Midway Ave	Replace manhole (no-PVC)
6	2347 Fairway Dr	Replace 4' of pipe from 177' to 181' downstream of MH 123+03
6	Bermuda Ave at Acapulco Rd	Hole is just west of MH 130+09 downstream towards 130+08. Reconfigure merge for NB pipe into MH 130+09 to improve flow.
1	Vistagrand Dr at Darius Way	Remove 5' of pipe adjacent to 192+19
1	San Rafael St at Emerald Ave	Raise manhole frame and cover to surrounding grade
1	San Rafael St at Elsie Ave	Raise manhole frame and cover to surrounding grade
2	14986 Patton Ave	Raise manhole frame and cover to surrounding grade
2	1480 Ave and Wake Ave	Raise manhole frame and cover to surrounding grade
2	13875 Velarde Dr	Raise manhole frame and cover to surrounding grade
2	Fulton Ave at Evergreen Ave	Raise manhole frame and cover to surrounding grade
2	1515 138th Ave	Raise manhole frame and cover to surrounding grade
2	14180 Rose Dr	Raise manhole frame and cover to surrounding grade
2	14220 Rose Dr	Raise manhole frame and cover to surrounding grade
2	Rose Dr at 139th Ave	Raise manhole frame and cover to surrounding grade
2	1395 139th Ave	Raise manhole frame and cover to surrounding grade
6	South of Marina Park near entrance to parcourse	Storm outfall repair
6	Preda St at Tulip Lane	Manhole replacement
5	Bancroft Ave between Dutton Ave and Oakes Blvd	Replace manhole frame and cover
2	1572 Halsey Ave	Repair City connection to County flood canal
5	551 Pala Ave	Storm drain pipe repair
1	Marina Blvd at San Leandro Blvd	Repair damaged sewer main
1	Santa Maria at Juana Ave	Replace brick manhole
1	397 Maud Ave	Construct new sewer manhole
5	450 Arroyo Ave	Replace brick manhole
6	Water Pollution Control Plant drying beds	Repair damaged asphalt concrete
3	Marina Blvd just east of I-880	Raise two manhole frames and covers that were buried beneath the pavement
3	1968 Alvarado Street	Emergency repair of clogged sewer main
3	Merced St at Fairway Dr	Repair of leaking sewer force main
1	W. Juana Ave between San Leandro Blvd and Carpentier St	Replace sewer main